



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)524-7605

FOR OFFICE USE ONLY
 Facility # 2-012966
 Permit # 01998-2007ABN
 Request Rec'd 11/28/2007
 Amended Date
 Approval Date 11/29/2007 JC
 Permit Expires 5/29/2008

Permit for ABANDONMENT IN PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to abandon in place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Graham C-Stores Company 33978 N. Highway 45, P.O. Box 89 Gages Lake, IL 60030-0089 Contact: Mike Graham (847) 223-3710</p>	<p>(2) FACILITY - name and address where tanks are located: Gages Lake Citgo 33978 N Hwy 45 Gages Lake, Lake Co., IL Contact: Jack Graham (847) 223-3710</p>
---	---

(3) ABANDONMENT IN PLACE OF TANKS:

- (a) *Number and size tanks being abandoned:* (TK # 1, 2, 3) - 5,000 gallons
- (b) *Location of tanks being abandoned:* CONTAMINATED SITE! IEMA Number: 071476

(4) This permit is VOID if contamination is revealed during abandonment procedures or if tanks are not as indicated on your granted permit site plan. If contamination is revealed, this abandonment can continue only when the contaminated site section (2) of the certification on site condition has been submitted to our Office.

(5) **SPECIAL CONTINGENCIES: Inspector must review the recent permits for this site to get a broader more comprehensive view of this job. Tanks 1,2,3 are in the tank field where there are three active tanks. Removing tank #3 would jeopardize tank #4 which is in use and contains E-85. Removing tanks 1 & 2 would jeopardize tanks 5 & 7 that sit next to these tanks and are active tanks. The tanks are also in near proximity to the canopy footins and building footings. A copy of the site assessment is on file.**

(6) **The owner must notify this Office when completion of tank abandonment has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.state.il.us/osfm or by calling (217)785-1020.**

<p>(7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u></p>	
<p>DRW Services, Inc. 600 E. Joe Orr Road Chicago Heights, IL 60411</p>	<p>Contact Person: Ray Kirchner Phone: (708) 758-3222 Contractor Registration # IL-194 Exp.</p>

Sincerely,

cc: Storage Tank Safety Specialist -
 Fire Department -
 Office Coordinator -
 Division File
 (Rev. - 1/98)