

OFFICE OF THE ILLINOIS STATE FIRE MARSHAL Division of Technical Services

1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)524-7605

FOR OFFICE USE ONLY

Facility # 2-001509
Permit # 01963-2007INS
Request Rec'd 11/06/2007
Amended Date
Approval Date 11/27/2007 JC
Permit Expires 5/27/2008

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE**.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:	(2) <u>FACILITY</u> - name and address where tanks are located:
Celli Leasing 2090 N. Mannheim Rd. Melrose Park, IL 60160	Celli Truck Center 2090 N. Mannheim Rd. Melrose Park, Cook Co., IL
Contact: Gene Celli (847) 678-3515	Contact: Gene Celli

(3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed: (TK # 4) 12,000 gallons
- (b) Type of tanks: (TK # 4) (Installing) XERXES double wall fiberglass
- (c) Type of piping: (TK # 4) (Installing) A.P.T. Poly Tech P100SC double wall flexible piping and (TK # 4) (Installing) A.P.T. Poly Tech P200SC double wall flexible
- (d) Product to be stored in each tank: (TK # 4) Used Oil
- (e) Type of leak detection being used:

Tank: (TK # 4) - (Installing) Veeder Root TLS 350 interstitial tank sensor, (TK # 4) - (Installing) Veeder Root TLS350 automatic tank gauge

Piping: (TK # 4) - (Installing) Veeder Root TLS350 interstitial piping sump sensor at tank sump only, (TK # 4) - (Installing) European Suction for the two lines coming from the tank to the building to feed the used oil heaters, (TK # 4) - (Installing) Gravity feed for the line(s) running from the two drain pits in the building to the tank

(f) Corrosion Protection being used:

Tank: (TK # 4) - (Installing) Fiberglass

Piping: (TK # 4) - (Installing) Non-corrosive flexible

- (g) Spill containment devices:
- (h) Overfill prevention devices:
- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.
- (5) **GENERAL REQUIREMENTS:**
- (6) SPECIAL CONTINGENCIES:

(7) PERSON, FIRM OR COMPANY PERFORMING WORK:		
	Contact Person: Phone:	
	Contractor Registration # IL-899	Exp.

Sincerely,

James of Coffey