



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 5-007418
Permit # 01961-2007UPG
Request Rec'd 11/26/2007
Amended Date
Approval Date 11/27/2007 JC
Permit Expires 5/27/2008

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Joseph F. Boente Sons, Inc. 543 W. Main Street, P.O. Box 288 Carlinville, IL 62626 Contact: David Boente (217) 854-3164	(2) FACILITY - name and address where tanks are located: J. F. Boente Sons 543 W. Main Carlinville, Macoupin Co., IL Contact: Boente David (217) 854-3164
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 7) - 6,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 7) - (Installing) partial A.P.T. Poly Tech P150SC double wall flexible (approximately 17' of new piping from a new transition sump next to the existing diesel dispenser, to a new satellite dispenser). There will be a short section of above ground piping coming from the existing dispenser to the new transition sump where it will connect to the new piping run.
- (d) *Product to be stored in each tank:* (TK # 7) - Diesel Fuel
- (e) *Type of leak detection being used:*
Tank:
Piping: (TK # 7) - (Installing) OPW EECO 2000 Interstitial piping sump sensors at the new transition sump and at the new satellite dispenser sump.
- (f) *Corrosion Protection being used:*
Tank:
Piping:
- (g) *Spill containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Contact Person: Phone: (217) 787-6081 Contractor Registration # Exp.
--

Sincerely,

Jim Coffey

