



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
3127453152

FOR OFFICE USE ONLY

Facility # 2020326
Permit # 02333-2019UPG
Request Rec'd 12/13/2019
Amended Date
Approval Date 12/15/2019
Permit Expires 6/16/2020

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

| | |
|--|--|
| <p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Kedzie BM Real Estate, Inc. 5547 N. Kedzie Ave. Chicago, IL 60625</p> <p>Contact: Stephen Chacko (773) 671-9864</p> | <p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Kedzie BM Real Estate, Inc. 5547 North Kedzie Chicago, IL 60625</p> <p>Contact: Stephen Chacko (773) 671-9864</p> |
|--|--|

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 2, 3) - 10,000, (TK # 4) - 12,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 2, 3, 4) Piping - Other Steel Riser*
- (d) Product to be stored in each tank: (TK # 2) - Gasoline - Premium, (TK # 3, 4) - Gasoline - Regular*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 2, 3, 4) Spill Contain Device - Single Wall Spill Bucket*
- (h) Overfill prevention devices: (TK # 2, 3, 4) Overfill Prev Device - Overfill Drop Tube Valve*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES** : we are installing new opw spill buckes, drop tubes and raisers from the top off the tanks due to test fail for spill buckets and drop tubes for 3 tanks

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

America Petropump Services LLC d/b/a Ampsco Services
4075 Fox Valley Center Dr., Unit 9
Aurora, IL 60504

Contact Person: Kiran Patibandla
Phone: (630) 649-8699
Contractor Registration # IL002420 Exp. 5/22/2021

Sincerely,


Chief Engineer-Storage Tank Section

Raul Valdivia

cc: Storage Tank Safety Specialist
Division File