



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

Amended

FOR OFFICE USE ONLY
Facility # 4-033819
Permit # 01907-2007UPG
Request Rec'd 11/14/2007
Amended Date 11/20/2007
Approval Date 11/15/2007 JC
Permit Expires 5/15/2008

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Meijer Great Lakes Limited Partnership 2929 Walker Avenue, NW Grand Rapids, MI 49544-9428 Contact: Lyle L. Livasy	(2) FACILITY - name and address where tanks are located: Meijer Gas Station #146 2201 N Prospect Champaign, Champaign Co., IL Contact: Team Leader (217) 353-4009 Ext. 479
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 5) - 4,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 5) - (Installing) A.O. Smith double wall fiberglass from new submersible pump to the existing island #5 / #6 (middle north island will have a new E-85 dispenser). See contingencies for reference of the existing kerosene piping run. This tank is converting from kerosene to E-85. The old kerosene dispenser and piping will be removed (will need a separate removal permit for the piping, if it is of substantial length and in a separate trench than the new E-85 run, or it can possibly be abandoned in place through an abandonment permit if the removal of it would cause any potential damage to active lines, tanks, underground utility systems, etc.).
- (d) *Product to be stored in each tank:* (TK # 5) - Kerosene
- (e) *Type of leak detection being used:*
Tank: (TK # 5) - (Installing) Veeder Root TLS350 automatic tank gauge probe only (for compatibility of the E-85) - see contingencies
Piping: (TK # 5) - (Installing) Veeder Root TLS350 electronic line leak detector, (TK # 5) - (Installing) Veeder Root TLS350 interstitial piping sump sensors at the submersible sump and the dispenser sump
- (f) *Corrosion Protection being used:*
Tank:
Piping:
- (g) *Spill containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Contact Person: Dean Mroczka Phone: Contractor Registration # IL-002211 Exp.

Sincerely,

James J. Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 1/98)