



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2036207
Permit # 02351-2019REM
Request Rec'd 12/17/2019
Amended Date
Approval Date 12/17/2019 DS
Permit Expires 6/17/2020

Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>CIMA Developers, LP 30W180 Butterfield Rd. Warrenville, IL 60555</p> <p>Contact: Dan Soltis (630) 653-1700</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Pride of Lake County 20915 Quentin Road Kildeer, IL 60047</p> <p>Contact: Dan Soltis (630) 668-0141</p>
---	--

(3) **REMOVAL OF PIPING:**

- (a) *Description/location of piping being removed:*
- (b) *Which tank(s) are associated with the piping being removed: (TK # 1, 2, 4) - 15,000*
- (c) *Reason of piping being removed:*
- (d) *If piping is leaking, indicate IEMA incident number:*

(4) After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) **SPECIAL CONTINGENCIES** : Under Upgrade permit 02251-2019UPG, the piping to dispensers #19/20 and #27-#32 will be replaced. The new pipe will use the pie trench of the existing pipe and that piping will be removed as encountered.

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

B & K Equipment Company
2939 175th Street
Lansing, IL 60438

Contact Person: Ed Angell
Phone: (708) 474-3344
Contractor Registration # IL1207 Exp. 12/17/2021

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist
Division File