



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 2046992  
Permit # 00014-2020REM  
Request Rec'd 01/06/2020  
Amended Date  
Approval Date 1/6/2020 DS  
Permit Expires 7/7/2020

**Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <b><u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Mia Property Acquisitions, LLC-6033 North LLC 3901 25th Avenue Schiller Park, IL 60176  Contact: Bart Przyjemski (773) 202-9819</p>	<p>(2) <b><u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Construction Site 6033 W. North Avenue Oak Park, IL 60302  Contact: George Kobylarcik (708) 225-1115</p>
--	---

(3) **REMOVAL OF TANKS:**

- (a) *Number and size of tanks being removed: (TK # 1) - 550*
- (b) *Description/location of piping being removed:*
- (c) *Product to be stored in each tank: (TK # 1) - Heating Oil*
- (d) *Reason of tanks being removed:*
- (e) *If tank(s) is leaking, indicate IEMA incident number:*
- (f) *Date each tank was last used: (TK # 1) - 12/31/1973*

(4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) **SPECIAL CONTINGENCIES** : Excavate to expose tank. Pump liquids from tank. Measure LEL or %oxygen, if greater than 5%, inert or vent the tank. Excavate to free tank. Hoist tank from the excavation and place on poly sheeting. re-test LEL or %oxygen. If greater than 5%, inert or vent the tank. If less than 5%, cut an opening in the tank and clean the interior of the tank. Place any solids in a drum. Place the tank on a trailer and transport it to a scrap yard to recycle the metal. Obtain appropriate soil samples and test for applicable IEPA regulations. Backfill the excavation and demobilize from the site.

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

Environmental Protection Industries, Inc.  
16650 South Canal Street  
South Holland, IL 60473

Contact Person: Eryn Barba  
Phone: (708) 225-1115  
Contractor Registration # IL564 Exp. 6/27/2020

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File