



Office of the Illinois State Fire Marshal
 Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 2177851020

Amended

FOR OFFICE USE ONLY
 Facility # 6045344
 Permit # 02391-2019INS
 Request Rec'd 12/18/2019
 Amended Date 01/13/2020 DS
 Approval Date 12/30/2019 DS
 Permit Expires 6/30/2020

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Pilot Travel Centers, LLC 5508 Lonas Rd. Knoxville, TN 379093221</p> <p>Contact: Joey Cupp (865) 588-7488</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Pilot Travel Center #1225 9810 Perrin Rd. Rt.4 @ I-64 Mascoutah, IL 62224</p> <p>Contact: Joey Cupp (865) 588-7488</p>
---	--

(3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed: (TK # 5, 6) - 20,000*
- (b) Type of tank(s): (TK # 5, 6) Tank - Fiberglass Double Wall XERXES*
- (c) Type of piping: (TK # 5, 6) Piping - Fiberglass Single Wall Piping Ameron Dualoy 3000L for venting, (TK # 5, 6) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX from tanks to blending shed, then from blending shed to the transition sump to connect to existing truck Diesel line, (TK # 5, 6) Piping - Other Steel Riser, (TK # 5, 6) Piping - Ball Valves, (TK # 5, 6) Piping - Extractor Fitting Valves, (TK # 5, 6) Piping - Shear Valves, (TK # 5, 6) Piping - Flex Connector Steel, (TK # 5, 6) Piping - Aboveground, (TK # 5, 6) Piping - Single Wall STP/Tanktop Sump, (TK # 5, 6) Piping - Single Wall Transition Sump, (TK # 5, 6) Piping - Blending Sump*
- (d) Product to be stored in each tank: (TK # 5) - Diesel Fuel, (TK # 6) - B-99*
- (e) Type of leak detection being used:*
 - Tank: (TK # 5, 6) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 Plus with CSLD, (TK # 5, 6) Leak Detect - Tank - Non-Discriminating Sensors Interstitial Monitoring, (TK # 6) Leak Detect - Tank - SIR and Prec Tightness Testing Warren Rogers Assoc. Petro Network S3 Version D*
 - Piping: (TK # 5) Leak Detect - Piping - Electronic Pressurized Line Leak Detection, (TK # 5, 6) Leak Detect - Piping - Non-Discriminating Sump Sensor in blending sump and in transition sump, (TK # 6) Leak Detect - Piping - European with No Test Req Suction*
- (f) Corrosion Protection being used:*
 - Tank: (TK # 5, 6) Corrosion Prot - Tank - Fiberglass Non-Corrosive*
 - Piping: (TK # 5, 6) Corrosion Prot - Piping - Fiberglass Non-Corrosive*
- (g) Spill containment devices, piping and dispenser containment devices: (TK # 5, 6) Spill Contain Device - Double Wall Spill Bucket*
- (h) Overfill prevention devices: (TK # 5, 6) Overfill Prev Device - Overfill Drop Tube Valve*

(4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov by calling (217)785-1020.

(5) GENERAL REQUIREMENTS : There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight

containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

(6) SPECIAL CONTINGENCIES :


Amendment Reason: Changed the layout for the new tanks and piping, no longer having remote fills for the new tanks.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Neumayer Equipment Company, Inc.
5060 Arsenal Street
St. Louis, MO 63139

Contact Person: Jimmy Spiros
Phone: (314) 772-4501
Contractor Registration # IL1502 Exp. 3/26/2020

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File