



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

<p align="center">FOR OFFICE USE ONLY</p> <p>Facility # 6026902 Permit # 02155-2019REM Request Rec'd 11/12/2019 Amended Date 01/15/2020 DS Approval Date 11/12/2019 DS Permit Expires 5/12/2020</p>
--

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Estate of Gerald E. Hess 16 W. Lorena Avenue Wood River, IL 62095 Contact: Rene Bassett-Butler (618) 216-5217</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Estate of Gerald E. Hess 2977 State Route 4 Marine, IL 62061 Contact: Hess Gerald (618) 633-2687</p>
--	---

(3) REMOVAL OF TANKS:

- (a) Number and size of tanks being removed: (TK # 7) - 1,000, (TK # 8) - 3,000*
- (b) Description/location of piping being removed:*
- (c) Product to be stored in each tank: (TK # 7) - Heating Oil, (TK # 8) - Gasoline*
- (d) Reason of tanks being removed:*
- (e) If tank(s) is leaking, indicate IEMA incident number:*
- (f) Date each tank was last used: (TK # 7, 8) - 8/25/2003*

(4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) SPECIAL CONTINGENCIES :

Amendment Reason: Additional UST was discovered.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
<p>Quality Testing and Engineering, Inc. 803 West State Street O Fallon, IL 62269</p>	<p>Contact Person: Wayne Smith Phone: (618) 632-9900 Contractor Registration # IL002355 Exp. 5/10/2020</p>

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist
Division File