



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

<b>FOR OFFICE USE ONLY</b>
Facility # 3040868
Permit # 00113-2020UPG
Request Rec'd 01/23/2020
Amended Date
Approval Date 1/23/2020 DS
Permit Expires 7/23/2020

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Kroger Limited Partnership I 5960 Castleway West Drive Indianapolis, IN 46250  Contact: Harley Ruger (317) 710-1212</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Fuel Center J-531 1405 West Garfield Avenue Bartonville, IL 61607  Contact: Devin Ferguson (309) 697-8811</p>
---	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 1) - 8,000, (TK # 2) - 20,000*
- (b) Type of tanks:*
- (c) Type of piping:*
- (d) Product to be stored in each tank: (TK # 1, 2) - Gasoline*
- (e) Type of leak detection being used:*  
*Tank:*  
*Piping:*
- (f) Corrosion Protection being used:*  
*Tank:*  
*Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices: (TK # 1, 2) Overfill Prev Device - Ball Only Removed Ball Float Vent Valve*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.


**(5) SPECIAL CONTINGENCIES :**

Removing ball floats on all tanks

**NOTE: Site has existing drop tubes, which must be set to 90% shut off if removing balls and leaving the cages**

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Illinois Oil Marketing Equipment, Inc. 850 Brenkman Drive Pekin, IL 61554	Contact Person: Chris Epkins Phone: (309) 347-1819

Sincerely,

  
\_\_\_\_\_

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File