



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

FOR OFFICE USE ONLY

Facility # 4007178
Permit # 02285-2019UPG
Request Rec'd 12/05/2019
Amended Date 02/03/2020 DS
Approval Date 12/5/2019 DS
Permit Expires 6/5/2020

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Sumark Normal, LLC 409 S. Prospect, Suite F Bloomington, IL 61704 Contact: Julia Davis (309) 585-3536</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Mac's #1204 309 Landmark Drive Normal, IL 61761 Contact: Carrie Burtis (630) 942-5363</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 2) - 10,000, (TK # 3, 4) - 8,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 2, 3, 4) Piping - Shear Valves, (TK # 3) Piping - Flexible Double Wall A.P.T. Poly Tech, (TK # 3) Piping - Flexible Double Wall OPW Flexworks*
- (d) Product to be stored in each tank: (TK # 2) - Gasoline - Regular, (TK # 3) - Gasoline - Premium, (TK # 4) - Diesel Fuel*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping: (TK # 3) Leak Detect - Piping - Non-Discriminating Sump Sensor*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Amendment Reason: Needing to remove existing product piping between premium tank #3 and the first dispenser it runs to with new OPW flexible piping. Replacing dispenser sump

Repair leaking APT coupling below dispenser #13/14. Install sump sensors in premium STP tank sump and dispenser #13/14 sump.

Amending permit - replacement of flexible line between Tank #3 and first dispenser with new OPW flexible piping. Will have chase pipe and

new bulkhead fittings installed as well at each of the sumps.


Amedning Permit - Installing new OPW Fiberglass SW Dispenser Sump and shear valves for dispenser #13/14. Will re-install existing product piping and dispenser. Repalcing island for this dispenser as well. Re-install exsiting sump sensor

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Neumayer Equipment Company, Inc.
5060 Arsenal Street
St. Louis, MO 63139

Contact Person: Jimmy Spiros
Phone: (314) 772-4501
Contractor Registration # IL1502 Exp. 3/26/2020

Sincerely,

A handwritten signature in cursive script that reads "Daniel H. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File