



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 4012411
Permit # 00171-2020INS
Request Rec'd 02/03/2020
Amended Date
Approval Date 2/3/2020 DS
Permit Expires 8/4/2020

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Ports Petroleum Company, Inc. P.O. Box 1046 Wooster, OH 44691 Contact: Stacy Beachy (330) 804-9115	(2) <u>FACILITY</u> - name and address where tanks are located: Fuel Mart #787 1207 E. Southline Rd. Tuscola, IL 61953 Contact: Crystal Holmes (330) 804-9126
--	---

(3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed: (TK # 11) - 12,000*
- (b) Type of tank(s): (TK # 11) Tank - Fiberglass Double Wall Containment Solutions*
- (c) Type of piping: (TK # 11) Piping - Flexible Double Wall Franklin Fueling Systems UPP from new tank to existing dispensers as shown in site plan , (TK # 11) Piping - Other Steel Riser, (TK # 11) Piping - Other Submersible Pump, (TK # 11) Piping - Ball Valves , (TK # 11) Piping - Extractor Fitting Valves , (TK # 11) Piping - Shear Valves , (TK # 11) Piping - Flex Connector Steel, (TK # 11) Piping - Single Wall STP/Tanktop Sump*
- (d) Product to be stored in each tank: (TK # 11) - Diesel Fuel*
- (e) Type of leak detection being used:*
 - Tank: (TK # 11) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 450 Plus , (TK # 11) Leak Detect - Tank - Non-Discriminating Sensors Interstitial Monitoring*
 - Piping: (TK # 11) Leak Detect - Piping - Electronic Pressurized Line Leak Detection, (TK # 11) Leak Detect - Piping - Non-Discriminating Sump Sensor in submersible sump and all dispenser sumps associated with this piping run*
- (f) Corrosion Protection being used:*
 - Tank: (TK # 11) Corrosion Prot - Tank - Fiberglass Non-Corrosive*
 - Piping: (TK # 11) Corrosion Prot - Piping - Flexible Non-Corrosive*
- (g) Spill containment devices, piping and dispenser containment devices: (TK # 11) Spill Contain Device - Single Wall Spill Bucket*
- (h) Overfill prevention devices: (TK # 11) Overfill Prev Device - Overfill Drop Tube Valve*

- (4)** The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov by calling (217)785-1020.
- (5) GENERAL REQUIREMENTS** : There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion

protection.


- (6) **SPECIAL CONTINGENCIES** : Original tank #6 is being removed and this tank is being set back in the same excavation, per contractor and site plan

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Lawrence Building Corporation
8401 Fritz Road
Fort Wayne, IN 46818

Contact Person: Nate Lawrence
Phone: (260) 469-8400
Contractor Registration # IL002416 Exp. 2/4/2021

Sincerely,

A handwritten signature in cursive script, reading "Daniel H. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File