



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2022802
Permit # 00219-2020UPG
Request Rec'd 02/11/2020
Amended Date
Approval Date 2/11/2020 DS
Permit Expires 8/11/2020

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Graham Enterprise, Inc. 750 Bunker Ct., Suite 100 Vernon Hills, IL 60061 Contact: John Graham (847) 837-0777	(2) <u>FACILITY</u> - name and address where tanks are located: BP Highland Park (SS# 278) 695 Central Avenue Highland Park, IL 60035 Contact: Mohamed Oiuuld Sidi Mohamed (847) 433-1866
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 8) - 12,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 8) Piping - Fiberglass Single Wall Piping Ameron , (TK # 8) Piping - Other Submersible Pump, (TK # 8) Piping - Ball Valves , (TK # 8) Piping - Flex Connector Steel, (TK # 8) Piping - Single Wall STP/Tanktop Sump*
- (d) Product to be stored in each tank: (TK # 8) - Gasoline - Regular*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

This is a replacement for Expired Permit # 01455-2019UPG

Excavate to top of tank # 8 West RUL. Remove existing Submerge pump, cut back existing singewall steel product piping by 4' to 5' Install new Bravo B422-48-S-01 singelwall fiberglass sump with WT lid. Retro fit existing singewall steel piping and extend into new sump with singelwall fiberglass Ameron piping. Install new 2" ball valve, flex connector and related steel fittings.


Install new FE Petro STP 150 VL2-1-1/2 submerge pumping unit. We will reuse existing Veeder Root WPPLD leak detector

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Stenstrom Petroleum Services Group
2422 Center Street
Rockford, IL 61108

Contact Person: Robert Stenstrom
Phone: (815) 398-6250
Contractor Registration # IL1890 Exp. 4/12/2020

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File