



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2013485
Permit # 00249-2020UPG
Request Rec'd 02/13/2020
Amended Date
Approval Date 2/18/2020 DS
Permit Expires 8/18/2020

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Akzo Nobel Coatings, Inc. 1 East Water Street Waukegan, IL 60085 Contact: Robert Flary (847) 687-7100	(2) <u>FACILITY</u> - name and address where tanks are located: Akzo Nobel Coatings Inc 1 East Water Street Waukegan, IL 60085 Contact: Cherylyn McHugh (847) 625-3370
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 62, 66, 70, 73, 76) - 12,000, (TK # 63, 77) - 9,000, (TK # 64, 65, 68, 69, 78) - 3,000, (TK # 67, 71, 72, 74, 75) - 6,000*
- (b) *Type of tanks:*
- (c) *Type of piping:*
- (d) *Product to be stored in each tank: (TK # 62, 63, 69, 71, 72, 73, 74, 75) - Hazardous Substance, (TK # 64, 76) - Methyl Ethyl Ketone, (TK # 65) - Methyl Isobutyl Ketone, (TK # 66) - Toluene, (TK # 67) - Isopropyl Alcohol, (TK # 68) - Diacetone Alcohol, (TK # 70) - Xylene, (TK # 77) - Acetone, (TK # 78) - Butyl Acetate*
- (e) *Type of leak detection being used:*
- Tank:*
- Piping:*
- (f) *Corrosion Protection being used:*
- Tank:*
- Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices: (TK # 62, 63, 64, 65, 66, 67, 68, 69, 70, 71, 72, 73, 74, 75, 76, 77, 78) Overfill Prev Device - Overfill Alarm*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES** : Overfill alarms being permitted

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Interstate Pump and Tank, LLC
901 Niagara Street
Waukesha, WI 531863817

Contact Person: Dan McMahon
Phone: (262) 524-8494

Sincerely,



Daniel H. Starks

Daniel Starks

cc: Storage Tank Safety Specialist
Division File