



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

|                            |
|----------------------------|
| <b>FOR OFFICE USE ONLY</b> |
| Facility # 1033925         |
| Permit # 00252-2020REM     |
| Request Rec'd 02/14/2020   |
| Amended Date               |
| Approval Date 2/18/2020 DS |
| Permit Expires 8/18/2020   |

**Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances.**

Permission to remove underground storage tank piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

|  |   |
|--|---|
| <p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Northern Illinois Service Company<br/>4781 Sandy Hollow Road<br/>Rockford, IL 61109</p> <p>Contact: Wayne Klinger (815) 874-4422</p> | <p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Sandy Hollow Quad Office<br/>4781 Sandy Hollow Road<br/>Rockford, IL 61109</p> <p>Contact: Paul Munson (815) 874-4422</p> |
|--|---|

**(3) REMOVAL OF PIPING:**

- (a) Description/location of piping being removed:*
- (b) Which tank(s) are associated with the piping being removed: (TK # 2) - 12,000*
- (c) Reason of piping being removed:*
- (d) If piping is leaking, indicate IEMA incident number:*

**(4)** After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

**(5) SPECIAL CONTINGENCIES :** Removing existing poly dispenser sump, poly submersible sump, and 15' flexible piping run for replacement. Environmental contractor to pull samples for report at time of removal inspection.

|   |   |
|---|---|
| <b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>   |   |
| <p>Howard Lee &amp; Sons Inc.<br/>4093 Perryville Road PO Box 446<br/>Cherry Valley, IL 61016</p> | <p>Contact Person: Vicky Buhl<br/>Phone: (815) 332-4966<br/>Contractor Registration # IL456 Exp. 7/9/2021</p> |

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File