



Office of the Illinois State Fire Marshal  
 Division of Petroleum and Chemical Safety  
 1035 Stevenson Drive  
 Springfield, IL 62703  
 2177851020

**FOR OFFICE USE ONLY**  
 Facility # 2005120  
 Permit # 00302-2020UPG  
 Request Rec'd 02/25/2020  
 Amended Date  
 Approval Date 2/25/2020 DS  
 Permit Expires 3/9/2020

**Permit for Emergency Repair Request on 2/25/2020**

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>City of Evanston          2020 Asbury Avenue          Evanston, IL 60201          Contact: Pedro Ulloa (847) 866-2938</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Fleet Service Dept.          2020 Asbury Avenue          Evanston, IL 60201          Contact: Pedro Ulloa (847) 866-2938</p>
---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired: (TK # 5) - 10,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 5) Piping - Other Steel Riser, (TK # 5) Piping - Flex Connector Steel*
- (d) *Product to be stored in each tank: (TK # 5) - Gasoline - Regular*
- (e) *Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) *Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

- Replacing flex connector for unleaded vent line at tank
- Installing new riser on extractor for unleaded vent


**NOTE: Water could enter the tank through leaking vent line**

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b></p> <p>Stenstrom Petroleum Services Group</p>	<p>Contact Person: Robert Stenstrom</p>
------------------------------------------------------------------------------------------------------	-----------------------------------------

2422 Center Street  
Rockford, IL 61108

Phone: (815) 398-6250  
Contractor Registration # IL1890 Exp. 4/12/2020

Sincerely,



Daniel S. Starks

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File