



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 4007060
Permit # 00335-2020UPG
Request Rec'd 03/02/2020
Amended Date
Approval Date 3/2/2020 DS
Permit Expires 9/2/2020

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Mac's Convenience Stores, LLC 550 Warrenville Rd., Suite 400 Lisle, IL 60532</p> <p>Contact: Mike Sawkiewicz (919) 774-6700 Ext. 6978</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Circle K #1300 2315 West Springfield Avenue Champaign, IL 61821</p> <p>Contact: Crystal Walker (812) 379-9227</p>
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 4, 5, 6) - 12,000, (TK # 7) - 4,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 4, 5, 6, 7) Piping - Flexible Double Wall OPW Flexworks from existing tanks to new dispensers as shown in site plan, (TK # 4, 5, 6, 7) Piping - Ball Valves, (TK # 4, 5, 6, 7) Piping - Shear Valves, (TK # 4, 5, 6, 7) Piping - Flex Connector Steel, (TK # 4, 5, 6, 7) Piping - Single Wall STP/Tanktop Sump, (TK # 4, 5, 6, 7) Piping - Polyethylene Chase*
- (d) *Product to be stored in each tank: (TK # 4, 5) - Gasoline - Regular, (TK # 6) - Gasoline - Premium, (TK # 7) - Diesel Fuel*
- (e) *Type of leak detection being used:*
- Tank:*
- Piping: (TK # 4, 5, 6, 7) Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown in all submersible and dispenser sumps*
- NOTE: Sensors must shut down the submersible pump supplying that line upon detection of a leak per 175.640 a) 1)*
- (f) *Corrosion Protection being used:*
- Tank:*
- Piping:*
- (g) *Spill containment devices, piping, and dispenser containmnt devices: (TK # 7) Spill Contain Device - Double Wall Spill Bucket*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Demo out existing islands to replace sumps and product piping. Once new sumps and product piping are installed will instal new islands and re-isntall existng dispensers

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Neumayer Equipment Company, Inc.
5060 Arsenal Street
St. Louis, MO 63139

Contact Person: Jimmy Spiros
Phone: (314) 772-4501
Contractor Registration # IL1502 Exp. 3/26/2020

Sincerely,

A handwritten signature in cursive script, reading "Daniel G. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File