



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 4014330
Permit # 00382-2020UPG
Request Rec'd 03/06/2020
Amended Date
Approval Date 3/9/2020 DS
Permit Expires 9/9/2020

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Minit Mart, LLC 165 Flanders Road Westborough, MA 015811032 Contact: Toni VonRuden (800) 225-9702	(2) <u>FACILITY</u> - name and address where tanks are located: Minit Mart Gilman #625 1401 U.S. Highway 24 W Gilman, IL 60938 Contact: Kristin Horn (815) 265-4702
--	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) Number and size of tanks being upgraded or repaired: (TK # 7) - 5,000

(b) Type of tanks:

(c) Type of piping:

(d) Product to be stored in each tank: (TK # 7) - Gasoline

(e) Type of leak detection being used:

Tank:

Piping:

(f) Corrosion Protection being used:

Tank:

Piping:

(g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 7) Spill Contain Device - Double Wall Spill Bucket

(h) Overfill prevention devices: (TK # 7) Overfill Prev Device - Overfill Drop Tube Valve

(i) Manway accessible at grade:

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Installing 1- new OPW 71S0-410C Overfill Device and knocking out the ball float valve.

Installing 1- new 5 Gallon OPW 1C-3112P Edge Double Wall Spillage Containment.

NOTE: Drop tubes must be set at 90% shut off

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:


Pemco Service Company, Inc.

Contact Person: William "Butch" VonDrehle

1040 East Second Street
Gilman, IL 60938

Phone: (815) 265-7364
Contractor Registration # IL1224 Exp. 2/26/2022

Sincerely,

A handwritten signature in cursive script, reading "Daniel H. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File