



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 3020750
Permit # 00385-2020UPG
Request Rec'd 03/02/2020
Amended Date
Approval Date 3/9/2020 DS
Permit Expires 9/9/2020

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>J.D. Streett & Company, Inc. 144 Weldon Parkway Maryland Heights, MO 63043 Contact: Darrell Meek (800) 678-6600</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Canton BP 510 E. Linn Canton, IL 61520 Contact: Sara Jansen (309) 647-5894</p>
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 3) - 15,000, (TK # 5) - 14,000, (TK # 6) - 6,000*
- (b) Type of tanks:*
- (c) Type of piping:*
- (d) Product to be stored in each tank: (TK # 3) - Gasoline - Regular, (TK # 5) - Diesel Fuel, (TK # 6) - Gasoline - Premium*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping: (TK # 3, 5, 6) Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices: (TK # 6) Spill Contain Device - Single Wall Spill Bucket*
- (h) Overfill prevention devices: (TK # 6) Overfill Prev Device - Overfill Drop Tube Valve*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Drop tube was unable to be pulled for inspection. Spill bucket seal integrity lost. Replacement of spill bucket and fill tube required. Adding positive shut down for all sump sensors

NOTE: No existing ball floats listed in our database.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:


Superior Acquisition LLC d/b/a Superior Equipment Company

Contact Person: Matt Gross
Phone: (314) 644-6000

7525-A Sussex
St. Louis, MO 63143

Contractor Registration # IL002394 Exp. 2/26/2021

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File