



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Technical Services  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)524-7605

FOR OFFICE USE ONLY  
Facility # 2-022344  
Permit # 01928-2007UPG  
Request Rec'd 11/16/2007  
Amended Date  
Approval Date 11/16/2007 JC  
Permit Expires 5/16/2008

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Governors State University Univ Pkwy & Governors Hwy University Park, IL 60466 Contact: Hassett Mike (708) 534-4515	<b>(2) FACILITY</b> - name and address where tanks are located: Governors State University Univ Pkwy & Governors Hwy University Park, Will Co., IL Contact: Hassett Mike (708) 534-4515
-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

**(3) UPGRADE OR REPAIR OF TANKS:**

(a) *Number and size of tanks being upgraded or repaired:* (TK # 2) - 4,000 gallons

(b) *Type of tanks:* (TK # 2) - Existing single wall fiberglass

(c) *Type of piping:* (TK # 2) - Existing single wall fiberglass

(d) *Product to be stored in each tank:* (TK # 2) - Gasoline

(e) *Type of leak detection being used:*

**Tank:** (TK # 2) - Existing automatic tank gauging, (TK # 2) - Existing groundwater monitoring, (TK # 2) - (Installing) one Vapor Monitoring sensor in one existing groundwater monitoring well due to the fact there is no more groundwater to monitor at this particular well, so the contractor will replace the existing sensor with a vapor sensor in the existing well. The other groundwater monitoring wells will remain as is.

**Piping:** (TK # 2) - Existing European Suction, (TK # 2) - Existing groundwater monitoring (see above statement referring to tank leak detection, and the contingencies section of this permit)

(f) *Corrosion Protection being used:*

**Tank:**

**Piping:**

(g) *Spill containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES:** There is one existing monitoring well at one of the corners of this tank, and one about midway of the piping run (next to the trench). The location of the well for this new permit must be noted on the inspector log for future reference

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Contact Person: Steve Hirsch

Phone:

Contractor Registration # IL-1594 Exp.

Sincerely,

