



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Extended

FOR OFFICE USE ONLY

Facility # 4014952
Permit # 01778-2019LIN
Request Rec'd 09/18/2019
Amended Date
Approval Date 9/18/2019 DS
Permit Expires 9/18/2020

Permit for INSPECTION OF INTERIOR LINING of Underground Storage Tank(s) for Petroleum and Hazardous Substances.

Permission to inspect existing interior lining of underground storage tank(s) is hereby granted. Such inspections of interior lining must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code, Parts 174, 175 and 176. Such inspections of interior lining shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Paul Bottles 40096 East 950 North Road Saybrook, IL 61770 Contact: Bottles Paul (309) 475-8461	(2) <u>FACILITY</u> - name and address where tanks are located: Paul Bottles 310 South Main Street Saybrook, IL 61770 Contact: Paul Bottles (309) 475-8461
--	--

(3) INSPECTION OF INTERIOR LINING OF TANKS:

(a) Number and size of tanks being inspected: (TK # 2) - 4,000, (TK # 3) - 1,000

(b) Type of tank(s):

(c) Product stored in each tank: (TK # 2) - Diesel Fuel, (TK # 3) - Gasoline

(d) Manway accessible at grade: (TK # 2) Existing, (TK # 3) Existing

- (4)** Any tank that has been out of service for a twelve-month consecutive period cannot be put back into service unless it meets all new UST upgrade regulations. This permit is for the inspection of the existing interior lining only. No repairing, upgrading, or interior lining is authorized with this permit.
- (5)** The owner must notify this Office when completion of tank interior inspection has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.
- (6) SPECIAL CONTINGENCIES** : Tank relining, lining inspection and entry permit work in reference to manways/manholes must abide by section 175.500. internal inspection of Tank 2 and Tank 3

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Bolin Enterprises, Inc.
506 North East 15th Street PO Box 70
Casey, IL 62420

Contact Person: Sara Brandenburg
Phone: (217) 932-4533
Contractor Registration # IL002333 Exp. 10/10/2020

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist
Division File