



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 6013027  
Permit # 00428-2020UPG  
Request Rec'd 03/13/2020  
Amended Date  
Approval Date 3/16/2020 DS  
Permit Expires 9/16/2020

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  PREM Investments, Inc. 526 Route 3 Cahokia, IL 62206  Contact: Ricky Singh (989) 392-0176	<b>(2) FACILITY</b> - name and address where tanks are located:  Route 3 Food & Fuel 526 Rt. 3 Cahokia, IL 62206  Contact: Ricky Singh (989) 392-0176
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired: (TK # 5, 6, 7) - 10,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 5, 6) Piping - Flexible Double Wall OPW Flexworks from existing tanks to dispensers as shown in site plan, (TK # 5, 6, 7) Piping - Ball Valves, (TK # 5, 6, 7) Piping - Shear Valves, (TK # 5, 6, 7) Piping - Flex Connector Steel, (TK # 5, 6, 7) Piping - Single Wall STP/Tanktop Sump, (TK # 5, 6) Piping - Polyethylene Chase*
- (d) *Product to be stored in each tank: (TK # 5) - Gasoline - Regular, (TK # 6) - Diesel Fuel, (TK # 7) - Gasoline - Premium*
- (e) *Type of leak detection being used:*  
  
*Tank:*  
  
*Piping: (TK # 5, 6, 7) Leak Detect - Piping - Non-Discriminating Sump Sensor in submersible and dispenser sumps*  
  
*NOTE: Sensors must shut down the submersible pump supplying that line upon detection of a leak per 175.640 a) 1)*
- (f) *Corrosion Protection being used:*  
  
*Tank:*  
  
*Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices: (TK # 6, 7) Spill Contain Device - Single Wall Spill Bucket*
- (h) *Overfill prevention devices: (TK # 6, 7) Overfill Prev Device - Overfill Drop Tube Valve*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES** : Re-install premium product line, install new diesel and nolead product line. Install new sumps, and sump sensors. Installing new spill buckets and drop tubes on premium an diesel tanks.

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**


Neumayer Equipment Company, Inc.

Contact Person: Jimmy Spiros

5060 Arsenal Street  
St. Louis, MO 63139

Phone: (314) 772-4501  
Contractor Registration # IL1502 Exp. 3/26/2020

Sincerely,



---

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File