



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

FOR OFFICE USE ONLY

Facility # 4002378
Permit # 00399-2020UPG
Request Rec'd 01/10/2020
Amended Date 03/24/2020 DS
Approval Date 3/11/2020 DS
Permit Expires 9/11/2020

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Pilot Travel Centers, LLC 5508 Lonas Rd. Knoxville, TN 37909 Contact: Joey Cupp (865) 588-7488	(2) <u>FACILITY</u> - name and address where tanks are located: Flying J Travel Plaza #643 1701 W. Evergreen Ave. Effingham, IL 62401 Contact: Mike Irwin (865) 588-7488
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 14) - 20,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 14) Piping - Steel Single Wall Piping , (TK # 14) Piping - Other Steel Riser, (TK # 14) Piping - Ball Valves , (TK # 14) Piping - Flex Connector Steel*
- (d) Product to be stored in each tank: (TK # 14) - Diesel Fuel*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping: (TK # 14) Leak Detect - Piping - European with No Test Req Suction*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 14) Spill Contain Device - Double Wall Spill Bucket*
- (h) Overfill prevention devices: (TK # 14) Overfill Prev Device - Overfill Drop Tube Valve*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Tank contains bio fuel, B-99. Currently it is a pressurized system with STP at the tank. Will remove STP and install steel pipe for suction stub in the tank, and re-work the piping in the bio shed to install suction pump and remove filter housing in the shed. Will install check valve after the suction pump to make it a safe suction system. Will use flex connectors to help make the connections and absorb and shacking form the suction pump. Will also be installing new spill container and dispenser hoses that are bio compatible.

Amendment Reason: Replacing drop tube on the bio tank as well.


NOTE: No existing ball float

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Neumayer Equipment Company, Inc.
5060 Arsenal Street
St. Louis, MO 63139

Contact Person: Jimmy Spiros
Phone: (314) 772-4501
Contractor Registration # IL1502 Exp. 3/26/2020

Sincerely,

A handwritten signature in cursive script that reads "Daniel H. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File