



**City of Chicago**  
**Department of Public Health**  
 333 South State Street, Room 200  
 Chicago, IL 60604  
 3127453162

**FOR OFFICE USE ONLY**  
 Facility # 2007782  
 Permit # 00521-2020UPG  
 Request Rec'd 03/31/2020  
 Amended Date  
 Approval Date 3/31/2020  
 Permit Expires 10/1/2020

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) <u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>AT&amp;T Corp. d/b/a Illinois Bell          308 S. Akard, Room 1700          Dallas, TX 75202</p> <p>Contact: Chantel McMorris (214) 236-5119</p>	<p><b>(2) <u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Dorchester CO          6050 South Dorchester          Chicago, IL 60637</p> <p>Contact: Chantel McMorris (313) 874-8979</p>
--	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 2) - 2,500*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 2) Piping - Other Steel Riser*
- (d) Product to be stored in each tank: (TK # 2) - Diesel Fuel*
- (e) Type of leak detection being used:*  
     *Tank:*  
     *Piping:*
- (f) Corrosion Protection being used:*  
     *Tank:*  
     *Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 2) Spill Contain Device - Single Wall Spill Bucket*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : Replace existing overspill with new 5 gallon Grade Level overspill. Will remove existing overfill drop tube and install new straight NON Flapper drop tube. Location has an extrenal overfill alarm next to tank

<b>(6) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u></b>	
Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108	Contact Person: Robert Stenstrom Phone: (815) 398-6250 Contractor Registration # IL1890 Exp. 3/7/2022

Sincerely,



Chief Engineer-Storage Tank Section

Raul Valdivia

cc: Storage Tank Safety Specialist  
Division File