



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2020132
Permit # 00564-2020UPG
Request Rec'd 04/10/2020
Amended Date
Approval Date 4/13/2020 DS
Permit Expires 10/14/2020

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Sam's West, Inc. 2101 SE Simple Savings Drive Bentonville, AR 727160745 Contact: Chris Stewart (479) 258-2364</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Sam's Club #6384 9500 W. Joliet Rd. Hodgkins, IL 60525 Contact: Anthony Horejs (479) 277-7113</p>
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 38, 39, 40) - 20,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 38, 39, 40) Piping - Flexible Double Wall OPW Flexworks from existing tanks to existing dispensers as well as to two new dispensers as shown in site plan, (TK # 38, 39, 40) Piping - Ball Valves, (TK # 38, 39, 40) Piping - Shear Valves, (TK # 38, 39, 40) Piping - Flex Connector Steel, (TK # 38, 39, 40) Piping - Single Wall STP/Tanktop Sump*
- (d) *Product to be stored in each tank: (TK # 38, 39, 40) - Gasoline*
- (e) *Type of leak detection being used:*
- Tank: (TK # 38, 39, 40) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD, (TK # 38, 39, 40) Leak Detect - Tank - Non-Discriminating Sensors Interstitial Monitoring*
- Piping: (TK # 38, 39, 40) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection, (TK # 38, 39, 40) Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown in all submersible and dispenser sumps*
- (f) *Corrosion Protection being used:*
- Tank:*
- Piping:*
- (g) *Spill containment devices, piping, and dispenser containmnt devices: (TK # 38, 39, 40) Spill Contain Device - Double Wall Spill Bucket*
- (h) *Overfill prevention devices: (TK # 38, 39, 40) Overfill Prev Device - Overfill Drop Tube Valve*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.
- (5) **SPECIAL CONTINGENCIES** : Expanding site and adding two new dispenser islands. Adding on to existing canopy. Upgrading all piping to new OPW Flexworks. Installing new spill buckets and drop tubes. Moving vent stack. New OPW tank and dispenser sumps. Reusing existing TLS450Plus but adding sensors to all sumps.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Stenstrom Petroleum Services Group
2422 Center Street
Rockford, IL 61108

Contact Person: Robert Stenstrom
Phone: (815) 398-6250
Contractor Registration # IL1890 Exp. 4/12/2022

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File