



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 6045344  
Permit # 00574-2020UPG  
Request Rec'd 04/14/2020  
Amended Date  
Approval Date 4/15/2020 DS  
Permit Expires 10/15/2020

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) <u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Pilot Travel Centers, LLC 5508 Lonas Rd. Knoxville, TN 37909  Contact: Joey Cupp (865) 588-7488</p>	<p><b>(2) <u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Pilot Travel Center #1225 9810 Perrin Rd. Rt.4 @ I-64 Mascoutah, IL 62224  Contact: Joey Cupp (865) 588-7488</p>
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

(a) *Number and size of tanks being upgraded or repaired: (TK # 2) - 20,000*

(b) *Type of tanks:*

(c) *Type of piping:*

*(TK # 2) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX from existing dispenser sumps to new dispensers as shown in site plan, (TK # 2) Piping - Shear Valves, (TK # 2) Piping - Flex Connector Steel*

*NOTE: UDC sumps must be installed under new dispensers*

(d) *Product to be stored in each tank: (TK # 2) - Diesel Fuel*

(e) *Type of leak detection being used:*

*Tank:*

*Piping: (TK # 2) Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown in new dispenser sumps*

*NOTE: Sensors must shut down the submersible pump supplying that line upon detection of a leak*

(f) *Corrosion Protection being used:*

*Tank:*

*Piping:*

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.


(5) **SPECIAL CONTINGENCIES** : Installing two new dispensers for the diesel truck canopy.

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

Neumayer Equipment Company, Inc.  
5060 Arsenal Street  
St. Louis, MO 63139

Contact Person: Jimmy Spiros  
Phone: (314) 772-4501  
Contractor Registration # IL1502 Exp. 3/26/2022

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a thin horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File