



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

FOR OFFICE USE ONLY

Facility # 2038296
Permit # 00267-2020UPG
Request Rec'd 02/19/2020
Amended Date 04/15/2020 DS
Approval Date 2/19/2020 DS
Permit Expires 8/19/2020

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Orange Crush Recycle LP 323 Center Street Hillside, IL 60162 Contact: Bob Nallen (708) 544-9440	(2) <u>FACILITY</u> - name and address where tanks are located: Orange Crush Recycle LP 321 Center Street Hillside, IL 60162 Contact: Vito Martel (708) 544-9440
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 3, 4) - 10,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 3, 4) Piping - Fiberglass Single Wall Piping Ameron , (TK # 3, 4) Piping - Flex Connector Steel, (TK # 3, 4) Piping - Single Wall STP/Tanktop Sump*
- (d) Product to be stored in each tank: (TK # 3) - Gasoline, (TK # 4) - Diesel Fuel*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping: (TK # 3, 4) Leak Detect - Piping - Non-Discriminating Sump Sensor*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :


Amendment Reason: It was determined the "double wall piping" was PVC and that is not allowed. Inspector suggested removing existing piping and dispenser sumps associated with tanks 3 & 4 and installing new piping

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

U.S. Venture, Inc.
425 Better Way

Contact Person: Larry Smarzinski
Phone: (920) 735-8249

Sincerely,

A handwritten signature in cursive script that reads "Daniel H. Starks". The signature is written in dark ink and is positioned above a thin horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File