



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

FOR OFFICE USE ONLY

Facility # 4003222
Permit # 00606-2020INS
Request Rec'd 04/21/2020
Amended Date 05/05/2020 DS
Approval Date 4/21/2020 DS
Permit Expires 10/21/2020

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Wortman Holdings, LLC P.O. Box 217 Effingham, IL 62401 Contact: Lisa Wortman (217) 342-7291</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Jack Flash - Altamont 1206 Main Street Altamont, IL 62411 Contact: Kelsey Brown (217) 342-7291</p>
---	--

(3) INSTALLATION OF TANKS:

- (a) *Number and size of tanks being installed: (TK # 12) - 15,000, (TK # 13, 14) - 5,000, (TK # 15) - 20,000, (TK # 16) - 6,000*
- (b) *Type of tank(s): (TK # 12, 13, 14, 15) Tank - Composite Double Wall Glasteel II, (TK # 16) Tank - Fiberglass Double Wall Containment Solutions*
- (c) *Type of piping: (TK # 12, 13, 14, 15) Piping - Flexible Double Wall OPW Flexworks from tanks to dispensers, (TK # 12, 13, 14, 15, 16) Piping - Other Steel Riser, (TK # 12, 13, 14, 15) Piping - Other Submersible Pump, (TK # 12, 14) Piping - Chase Secondary Containment OPW AXP - 4" secondary chase piping, (TK # 12, 14) Piping - Chase Secondary Containment OPW Geoduct non-corrosive flexible secondary piping, (TK # 12, 13, 14, 15, 16) Piping - Ball Valves, (TK # 12, 13, 14, 15) Piping - Shear Valves, (TK # 12, 13, 14, 15) Piping - Flex Connector Steel, (TK # 12, 13, 14, 15) Piping - Single Wall STP/Tanktop Sump Petroleum Containment Inc. 4500 Series, (TK # 13, 15) Piping - Polyethylene Chase, (TK # 16) Piping - Fiberglass Single Wall Piping Ameron Dualoy 3000L, (TK # 16) Piping - Single Wall STP/Tanktop Sump Containment Solutions Fiberglass*
- (d) *Product to be stored in each tank: (TK # 12) - Gasoline - Regular, (TK # 13) - Gasoline - Non Ethanol, (TK # 14) - Gasoline - Premium, (TK # 15) - B-11, (TK # 16) - Diesel Exhaust Fluid (Non-Regulated)*
- (e) *Type of leak detection being used:*
 - Tank: (TK # 12, 14, 15, 16) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD, (TK # 12, 14, 16) Leak Detect - Tank - Interstitial Monitoring Veeder Root TLS 450 Plus, (TK # 13) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 450 with CSLD, (TK # 13, 15) Leak Detect - Tank - Non-Discriminating Sensors Interstitial Monitoring*
 - Piping: (TK # 12, 13, 14, 15) Leak Detect - Piping - Electronic Pressurized Line Leak Detection Veeder Root TLS 450 Plus, (TK # 12, 14) Leak Detect - Piping - Non-Discriminating Sump Sensor Veeder Root, (TK # 13, 15) Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown, (TK # 16) Leak Detect - Piping - Piping Sump Sensors Not Regulated Not Installed*
- (f) *Corrosion Protection being used:*
 - Tank: (TK # 12, 13, 14, 15) Corrosion Prot - Tank - Composite Non-Corrosive, (TK # 16) Corrosion Prot - Tank - Fiberglass Non-Corrosive*
 - Piping: (TK # 12, 13, 14, 15) Corrosion Prot - Piping - Flexible Non-Corrosive, (TK # 16) Corrosion Prot - Piping - Fiberglass Non-Corrosive*
- (g) *Spill containment devices, piping and dispenser containment devices: (TK # 12, 13, 14, 15) Spill Contain Device - Single Wall Spill Bucket OPW 1C-2100C-PEVR, (TK # 16) Spill Contain Device - Field Constructed OPW 211*

(h) *Overfill prevention devices: (TK # 12, 13, 14, 15) Overfill Prev Device - Overfill Drop Tube Valve OPW 71SO-410C, (TK # 16) Overfill Prev Device - Ball Float Vent Valve*


- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.
- (5) **GENERAL REQUIREMENTS** : There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.
- (6) **SPECIAL CONTINGENCIES** :
Amendment Reason: Inspector Travis Smith said these changes are needed Travis Smith requested changing tank #13 to "Ethanol Free Gasoline" and Tank #15 to "Bio Diesel" He also requested a new installation drawing to reflect a different tank layout than what is shown.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

UPC Enterprises, LC d/b/a United Petroleum Service
4444 Union Blvd.
St. Louis, MO 63115

Contact Person: Terry Smith
Phone: (314) 241-3767
Contractor Registration # IL002402 Exp. 2/10/2022

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File