



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Extended/Amended

FOR OFFICE USE ONLY

Facility # 5020789
Permit # 02095-2019UPG
Request Rec'd 10/30/2019
Amended Date 05/06/2020 DS
Approval Date 11/4/2019 DS
Permit Expires 11/5/2020

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Illinois Ayers Oil Company 6900 Hwy 24 East @ I-172 Quincy, IL 62306</p> <p>Contact: Curt Adams (217) 434-8662</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Ayerco #5 Convenience Center Highway 24, 20 West Wood Camp Point, IL 62320</p> <p>Contact: Carl Carl Adams Jr (217) 434-8662</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 2) - 6,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 2) Piping - Flexible Double Wall A.P.T. Poly Tech P200SC from existing tank to new dispenser as shown in drawing, (TK # 2) Piping - Single Wall STP/Tanktop Sump*
- (d) Product to be stored in each tank: (TK # 2) - Diesel Fuel*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping: (TK # 2) Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown in submersible and new dispenser sump*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices: (TK # 2) Overfill Prev Device - Overfill Alarm Veeder Root TLS 350*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Amendment Reason: Customer wants to add a Island for Diesel trucks. The Island would be directly next to the Diesel tank and piping would only be 6 to 8 ft run.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

All Line Equipment, Inc.

Contact Person: Steve Disselhorst

5519 Skyline Drive, PO Box 5257
Quincy, IL 62305

Phone: (217) 224-9725
Contractor Registration # IL002319 Exp. 12/23/2019

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File