



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 7007983  
Permit # 00681-2020UPG  
Request Rec'd 05/07/2020  
Amended Date  
Approval Date 5/11/2020 DS  
Permit Expires 11/12/2020

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) <u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>HPT TA Properties, LLC 24601 Center Ridge Road Westlake, OH 44145  Contact: Rob Porges (440) 808-7268</p>	<p><b>(2) <u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Travel Centers of America 4510 Broadway PO Box 943 Mount Vernon, IL 62864  Contact: Tiffani Walden (440) 808-7368</p>
--	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 2, 3, 4, 5, 8) - 20,000*
- (b) Type of tanks:*
- (c) Type of piping:*
- (d) Product to be stored in each tank: (TK # 2, 3, 4) - Diesel Fuel, (TK # 5) - Gasoline - Regular, (TK # 8) - Gasoline - Premium*
- (e) Type of leak detection being used:*
  - Tank:*
  - Piping: (TK # 2, 3, 4, 5, 8) Leak Detect - Piping - Electronic Pressurized Line Leak Detection*
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

Changing from mechanical to electronic line leak detection.

**NOTE:** This permit doesn't specifically address any of the violations on the active NOV so I reached out to the contractor and I got this response, therefore I issued the permit. - "Spoke with the customer. They said everything was uploaded to the portal this weekend and that they spoke with Travis and he said everything was good except this permit."

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Contact Person: Keri Hankins

Seneca Companies, Inc.  
4140 East 14th Street PO Box 3360  
Des Moines, IA 50313

Phone: (816) 761-1270  
Contractor Registration # IL598 Exp. 2/23/2022

Sincerely,

A handwritten signature in cursive script that reads "Daniel H. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File