



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 3000255
Permit # 00718-2020UPG
Request Rec'd 05/14/2020
Amended Date
Approval Date 5/14/2020 DS
Permit Expires 11/16/2020

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Navpreet Singh 726 Prince Street Pekin, IL 61554</p> <p>Contact: Navpreet (Sunny Singh) (917) 935-5449</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Lovely Food Mart, Inc. d/b/a Glen Oak Quick Stop 1213 East McClure Peoria, IL 61603</p> <p>Contact: Mike Elsayegh (917) 935-5449</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired: (TK # 8) - 6,000, (TK # 9) - 3,000*

(b) *Type of tanks:*

(c) *Type of piping: (TK # 8, 9) Piping - Flexible Double Wall A.P.T. Poly Tech P175SC from existing tanks to dispensers as shown in site plan, (TK # 8, 9) Piping - Extractor Fitting Valves, (TK # 8, 9) Piping - Shear Valves*

(d) *Product to be stored in each tank: (TK # 8, 9) - Gasoline*

(e) *Type of leak detection being used:*

Tank:

Piping: (TK # 8, 9) Leak Detect - Piping - Non-Discriminating Sump Sensor in all submersible and dispenser sumps. Existing LLD to be re-used

NOTE: Sensors must be wired for positive shut down

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containment devices: (TK # 8, 9) Spill Contain Device - Single Wall Spill Bucket*

(h) *Overfill prevention devices: (TK # 8, 9) Overfill Prev Device - Overfill Drop Tube Valve*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Replaced piping exceeds 20 feet or 50% of the total pipe run.

This site was started by a previous contractor. They permitted the removal of old piping and sampling. We are installing (2) new Franklin Fueling UDC sumps, new APT piping shear valves, spill buckets, droptubes. Tanks will be tested after new components are installed.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Seneca Companies, Inc.
4140 East 14th Street PO Box 3360
Des Moines, IA 50313

Contact Person: Keri Hankins
Phone: (816) 761-1270
Contractor Registration # IL598 Exp. 2/23/2022

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File