



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2027746
Permit # 00722-2020ABN
Request Rec'd 04/11/2020
Amended Date
Approval Date 5/18/2020 DS
Permit Expires 11/18/2020

Permit for ABANDONMENT IN PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to abandon in place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Oak Park Hospital 520 South Maple Avenue Oak Park, IL 60304</p> <p>Contact: Larry Moser (708) 660-2164</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Oak Park Hospital 514 South Harlem Avenue Oak Park, IL 60304</p> <p>Contact: David Benning (708) 660-2164</p>
---	--

(3) **ABANDONMENT IN PLACE OF TANKS:**

- (a) *Number and size tanks being abandoned: (TK # 1, 2) - 10,000*
- (b) *Product stored in each tank: (TK # 1, 2) - Diesel Fuel*
- (c) *Location of tanks being abandoned: The building does not have a footing which makes for more of a stability issue during a removal. The distance from the building to the tanks is approximately 7' and from the tank to the sidewalk is approximately 6'. There are overhead power lines run over the entire area and also underground utilities along the entire length where the tanks are located.*
- (d) *Location of piping being abandoned:*

(4) This permit is VOID if contamination is revealed during abandonment procedures or if tanks are not as indicated on your granted permit site plan. If contamination is revealed, this abandonment can continue only when the contaminated site section (2) of the certification on site condition has been submitted to our Office.

(5) **SPECIAL CONTINGENCIES :**

(6) **The owner must notify this Office when completion of tank abandonment has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.**

<p>(7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u></p>	
<p>B & B Construction & Excavating Company 1288 East Bungalow Road Morris, IL 60450</p>	<p>Contact Person: Linda Goldsmith Phone: (815) 416-1330 Contractor Registration # IL1602 Exp. 10/6/2020</p>

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist
Division File