

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety 1035 Stevenson Drive Springfield, IL 62703 2177851020

### FOR OFFICE USE ONLY

Facility # 2029707 Permit # 00743-2020INS Request Rec'd 05/19/2020 Amended Date Approval Date 5/20/2020 DS Permit Expires 11/20/2020

### Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE**.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:	(2) <u>FACILITY</u> - name and address where tanks are located:
Walayat, LLC 2100 W. Army Trail Road Addison, IL 60101	Army Trail Gas & Food, Inc. 2100 W. Army Trail Road Addison, IL 60101 Contact: Mazhar Hussain (773) 294-2482

#### (3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed: (TK # 4) 15,000, (TK # 5) 8,000, (TK # 6) 7,000
- (b) Type of tank(s): (TK # 4, 5, 6) Tank Composite Double Wall Lannon
- (c) Type of piping: (TK # 4, 5, 6) Piping Fiberglass Double Wall Ameron Dualoy 3000/LCX from tanks to dispensers as shown in site plan, (TK # 4, 5, 6) Piping Single Wall STP/Tanktop Sump Bravo B-407-PP
- (d) Product to be stored in each tank: (TK # 4) Gasoline Regular, (TK # 5) Gasoline Premium, (TK # 6) Diesel Fuel
- (e) Type of leak detection being used:
  - Tank: (TK # 4, 5, 6) Leak Detect Tank Automatic Tank Gauging Veeder Root TLS 350, (TK # 4, 5, 6) Leak Detect Tank -Interstitial Monitoring Veeder Root 794380-344 micro sensor
  - Piping: (TK # 4, 5, 6) Leak Detect Piping Electronic Pressurized Line Leak Detection Veeder Root TLS 350 PLLD leak sensors, (TK # 4, 5, 6) Leak Detect Piping Stand Alone Sensor Sump Sensor Veeder Root TLS 350 non-discriminating in all submersible and dispenser sumps
    - NOTE: Sensors must be wired for positive shut down
- (f) Corrosion Protection being used:

Tank: (TK # 4, 5, 6) Corrosion Prot - Tank - Composite Non-Corrosive

Piping: (TK # 4, 5, 6) Corrosion Prot - Piping - Fiberglass Non-Corrosive

- (g) Spill containment devices, piping and dispenser containment devices: (TK # 4, 5, 6) Spill Contain Device Single Wall Spill Bucket OPW 1-2100C DEVR
- (h) Overfill prevention devices: (TK # 4, 5, 6) Overfill Prev Device Overfill Drop Tube Valve OPW 71SO-400C
- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.govor by calling (217)785-1020.
- (5) <u>GENERAL REQUIREMENTS</u>: There shall be a minimum of two manufactured slotted or perforated observation wells of at lease 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut

off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

# (6) <u>SPECIAL CONTINGENCIES</u> :

# (6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Constellation Petroleum 27W441 Williams St. Winfield, IL 601901518 Contact Person: Mohammed Hussain Phone: (773) 507-0221 Contractor Registration # IL002438 Exp. 5/9/2021

Sincerely,

Daniel J. Starke

Daniel Starks

cc: Storage Tank Safety Specialist Division File