



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 4024298
Permit # 00778-2020UPG
Request Rec'd 05/28/2020
Amended Date
Approval Date 5/28/2020 DS
Permit Expires 12/1/2020

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Sprint Communications 6100 Sprint Parkway Overland Park, KS 66251</p> <p>Contact: Nikki Latin (913) 794-4814</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Sprint Communications 120 North Western Avenue Bloomington, IL 61701</p> <p>Contact: Dale Ray/B Operator (217) 663-9789</p>
---	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) Number and size of tanks being upgraded or repaired: (TK # 1) - 1,000

(b) Type of tanks:

(c) Type of piping: (TK # 1) Piping - Single Wall STP/Tanktop Sump

(d) Product to be stored in each tank: (TK # 1) - Diesel Fuel

(e) Type of leak detection being used:

Tank:

Piping:

(f) Corrosion Protection being used:

Tank:

Piping:

(g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 1) Spill Contain Device - Double Wall Spill Bucket

(h) Overfill prevention devices: (TK # 1) Overfill Prev Device - Overfill Drop Tube Valve

(i) Manway accessible at grade:

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES : This site is an emergency generator site that is existing, the site failed a tank tightness test and the entire tank had to be uincovered. A phone call was made so that the work to uncover could be completed. An application for a emergency repair permit was submitted for the items that needed repaired or replaced. It was found that the manwy gasket and bolts needed replaced and that would be covered under the emergency repair permit. The existing overspill was busted removing concrete and will be replaced with a OPW Edge DW overspill with sensor and connected to the existing ATG. The fill riser will be replaced with a schedule 40 riser. Due to the change in the overspill the existing overfill valve will be replaced with an OPW 71SO overfill prevention valve. The existing vent riser was not 2" and will be replaced with a 2" schedule 40 riser that extends 12' above grade. The tank sump top ring and lid will be replaced and the installation of a new surface manhole will be completed. Tanknology will be completing a tank and line tightness test as well. Please let me know if you have any questions. Scott Phone #217-251-6094 Thanks

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Bolin Enterprises, Inc.
506 North East 15th Street PO Box 70
Casey, IL 62420

Contact Person: Sara Brandenburg
Phone: (217) 932-4533
Contractor Registration # IL002333 Exp. 10/10/2020

Sincerely,

A handwritten signature in cursive script that reads "Daniel H. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File