



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2005467
Permit # 00785-2020UPG
Request Rec'd 05/31/2020
Amended Date
Approval Date 6/1/2020 DS
Permit Expires 12/1/2020

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Little Company of Mary Hospital 2800 W. 95th Street Evergreen Park, IL 60642 Contact: Roy Hupke (708) 229-5241</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Little Company of Mary Hospital 2800 W. 95th Street Evergreen Park, IL 60805 Contact: Ray Hupke (708) 229-5241</p>
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 6) - 10,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 6) Piping - Flexible Double Wall OmegaFlex DoubleTrac*
- (d) Product to be stored in each tank: (TK # 6) - Diesel Fuel*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping: (TK # 6) Leak Detect - Piping - European with No Test Req Suction*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

The underground tank has (1) existing 1 inch fuel supply line to the building generator. The existing fuel line will be replaced by the new. The new pipe will be (10 1 inch Omegaflex brand pipe from the UST to the building. The route for the new pipe is not in the same trench as the old pipe. When the new pipe is installed the old pipe will be disconnected form the tank and drained and then abandoned in place under a separate permit. The change over from the old pipe to the new pipe will happen within a few hours so as not to take the generator system off line for more than 2 hours. There is no change to the tank top containment. The tank top containment is only a cyliner to keep gravel away and not a containment sump.

There is NO change to the vent pipe, fill or other fuel system components. There is NO fuel return line.

Replaced piping exceeds 20 feet or 50% of the total pipe run.


NOTE: A removal permit must be obtained for the old piping that is being replaced

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Crowne Industries, Ltd.
651 S. Sutton Road #214
Streamwood, IL 60107

Contact Person: Robert Sumoski
Phone: (630) 497-9009
Contractor Registration # IL002345 Exp. 5/16/2022

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File