



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY
Facility # 2014287
Permit # 00812-2020REL
Request Rec'd 06/03/2020
Amended Date
Approval Date 6/4/2020 DS
Permit Expires 12/4/2020

Permit for INTERIOR LINING of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to internally line underground storage tank(s) or piping is hereby granted. Such interior lining must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. Such interior lining shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Markham Petroleum Company 201 Burr Ridge Club Burr Ridge, IL 60527 Contact: Bill Stefan (630) 750-1966</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>King Gas 1600 Ridgeland Ave. Berwyn, IL 60402 Contact: Mohammad Habib (708) 484-0902</p>
--	--

(3) INTERIOR LINING OF TANKS:

- (a) Number and size of tanks being internally lined: (TK # 8) - 4,000*
- (b) Type of tank(s):*
- (c) Name of manufacturer of internal lining material: Bridgeport Chemical*
- (d) Designation of internal lining material: Impervious 1 GA27P*
- (e) Product to be stored in each tank: (TK # 8) - Diesel Fuel*
- (f) Manway accessible at grade: (TK # 8) Install*

(4) This permit is VOID if tank is unacceptable for interior lining. Any tank that has been out of service for a twelve month consecutive period cannot be put back into service unless it meets all new UST upgrade regulations. This permit is for interior lining and manway installation only. Separate permits are required to do interior tank lining inspections.

(5) The owner must notify this Office when completion of tank internal lining has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov by calling (217)785-1020.

(6) SPECIAL CONTINGENCIES : Tank relining, lining inspection and entry permit work in reference to manways/manholes must abide by section 175.500.

Ethanol Compatibility lining

NOTE: Per section 175.415 d) lining for compatibility is allowed

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
<p>Tank Tech, Inc. 3975 State Highway H Sikeston, MO 63801</p>	<p>Contact Person: Jonathan McNeely Phone: (573) 471-1932 Contractor Registration # IL2136 Exp. 1/22/2022</p>

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist
Division File