



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 4014487  
Permit # 00813-2020UPG  
Request Rec'd 06/04/2020  
Amended Date  
Approval Date 6/4/2020 DS  
Permit Expires 12/4/2020

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) <u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>City of Champaign 702 Edgebrook Drive Champaign, IL 61820</p> <p>Contact: Tom Schuh (217) 403-4710</p>	<p><b>(2) <u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Champaign Public Works 702 Edgebrook Dr Champaign, IL 61820</p> <p>Contact: Steve Simon (217) 351-4450</p>
---	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired: (TK # 6, 7) - 9,520*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 6, 7) Piping - Fiberglass Double Wall Ameron Dualoy 3000/L from existing tanks to existing dispenser locations as shown in site plan*
- (d) *Product to be stored in each tank: (TK # 6) - Gasoline - Regular, (TK # 7) - Diesel Fuel*
- (e) *Type of leak detection being used:*

*Tank:*

*Piping: (TK # 6, 7) Leak Detect - Piping - Non-Discriminating Sump Sensor in all submersible and dispenser sumps*

*NOTE: Sensors must be wired for positive shut down*

- (f) *Corrosion Protection being used:*

*Tank:*

*Piping:*

- (g) *Spill containment devices, piping, and dispenser containmnt devices: (TK # 6, 7) Spill Contain Device - Single Wall Spill Bucket*
- (h) *Overfill prevention devices: (TK # 6, 7) Overfill Prev Device - Overfill Drop Tube Valve*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

Installing new stainless steel island. Installing new Gasboy dispensers, OPW dispenser sumps and Incon sump sensors. Installing new OPW tank sumpswith Incon sump sensors and new Ameron 3000L dual wall piping. Installing new OPW 1-2100 PEVR 5 gallon spill containers and OPW 71SO 400C overfill valves.

Replaced piping exceeds 20 feet or 50% of the total pipe run.

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Pemco Service Company, Inc.  
1040 East Second Street  
Gilman, IL 60938

Contact Person: William "Butch" VonDrehle  
Phone: (815) 265-7364  
Contractor Registration # IL1224 Exp. 2/26/2022

Sincerely,

A handwritten signature in cursive script, reading "Daniel G. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File