



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY
Facility # 7029079
Permit # 00827-2020UPG
Request Rec'd 06/05/2020
Amended Date
Approval Date 6/9/2020 DS
Permit Expires 12/9/2020

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Trail of Tears Lodge 1575 Fair City Road Jonesboro, IL 62952</p> <p>Contact: Debra Charles (618) 833-8697</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Pajco, Inc d/b/a/ Rhodes 101 Stop #410 148 Leigh Ave Anna, IL 629062202</p> <p>Contact: Cheryl Wren (618) 833-5433</p>
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 1) - 15,000, (TK # 3) - 12,000, (TK # 4) - 8,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 1, 3, 4) Piping - Partial Fiberglass Single Wall Piping Ameron Dualoy 3000L to accomodate new sumps, (TK # 1, 3, 4) Piping - Shear Valves, (TK # 1, 3, 4) Piping - Flex Connector Steel*
- (d) Product to be stored in each tank: (TK # 1, 3) - Gasoline, (TK # 4) - Diesel Fuel*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Remove dispenser #1/3 and #8 from island, demo islands and excavate down. Cut back SW FRP pipe install new OPW SW FRP Dispenser Sump. Install new SW FRP pipe into sump, install new flex connectors and shear valves. Install new island, replace concrete, reinstall existing dispenser.


NOTE: Leak detection testing to be done at time of work to address the NOV per contractor

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Neumayer Equipment Company, Inc.
5060 Arsenal Street
St. Louis, MO 63139

Contact Person: Jimmy Spiros
Phone: (314) 772-4501
Contractor Registration # IL1502 Exp. 3/26/2022

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File