



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2010917
Permit # 00845-2020UPG
Request Rec'd 06/12/2020
Amended Date
Approval Date 6/15/2020 DS
Permit Expires 12/15/2020

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: CIMA Developers, LP 30W180 Butterfield Rd. Warrenville, IL 60555 Contact: Dan Soltis (630) 653-1700	(2) <u>FACILITY</u> - name and address where tanks are located: Pride of Carol Stream 260 South Schmale Road Carol Stream, IL 60188 Contact: Dan Soltis (630) 668-7483
---	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired: (TK # 3) - 10,000, (TK # 4, 5, 6) - 12,000*

(b) *Type of tanks:*

(c) *Type of piping: (TK # 3, 4, 5, 6) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX, (TK # 3, 4, 5, 6) Piping - Shear Valves, (TK # 6) Piping - Other Submersible Pump, (TK # 6) Piping - Single Wall STP/Tanktop Sump*

(d) *Product to be stored in each tank: (TK # 3, 4, 5) - Gasoline, (TK # 6) - Ultra Low Sulfur Diesel*

(e) *Type of leak detection being used:*

Tank:

Piping: (TK # 6) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection, (TK # 6) Leak Detect - Piping - Non-Discriminating Sump Sensor

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Installing DEF tank, adding a new diesel product line from the existing diesel tank to feed new diesel/def dispensers. Re-configuring the existing diesel fueling positions under the west canopy.


NOTES: DEF tank does not need a permit to install. There must be sensors installed at all sumps where piping is being installed of not already existing and must be wired for positive shut down

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Crowne Industries, Ltd.
651 S. Sutton Road #214
Streamwood, IL 60107

Contact Person: Robert Sumoski
Phone: (630) 497-9009
Contractor Registration # IL002345 Exp. 5/16/2022

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File