



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2041728
Permit # 00847-2020UPG
Request Rec'd 06/15/2020
Amended Date
Approval Date 6/15/2020 DS
Permit Expires 12/15/2020

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: WELBIC III Aurora 3883, LLC 970 N. Oaklawn Ave., Ste 100 Elmhurst, IL 60126 Contact: Kristie Moran (630) 782-9520	(2) FACILITY - name and address where tanks are located: FedEx Freight, Inc.-AUR 3883 Butterfield Rd. Aurora, IL 605026893 Contact: Matt Sonkovitch (630) 820-6429
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 1) - 20,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 1) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX, (TK # 1) Piping - Positive Shutoff Valves, (TK # 1) Piping - Shear Valves, (TK # 1) Piping - Flex Connector Steel*
- (d) Product to be stored in each tank: (TK # 1) - Diesel Fuel*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

The dispenser islands will be replaced to accommodate the replacement of all dispenser sumps. New double walled fiberglass piping will be installed between all new dispenser sumps. All dispenser sump sensors will be set for positive shut-down.

Replaced piping exceeds 20 feet or 50% of the total pipe run.


NOTE: Site has existing sensors which will be wired for positive shut down

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

B & K Equipment Company
2939 175th Street
Lansing, IL 60438

Contact Person: Ed Angell
Phone: (708) 474-3344
Contractor Registration # IL1207 Exp. 2/14/2022

Sincerely,

A handwritten signature in cursive script, reading "Daniel G. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File