



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 1024403
Permit # 00856-2020UPG
Request Rec'd 06/15/2020
Amended Date
Approval Date 6/16/2020 DS
Permit Expires 12/16/2020

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>810 Bains Holding Inc. 810 Blackhawk Blvd. South Beloit, IL 61080</p> <p>Contact: Jaswinder Bains (608) 566-6655</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>810 Bains Holding Inc. 810 Blackhawk Boulevard South Beloit, IL 61080</p> <p>Contact: Raj Bainsi (608) 566-6655</p>
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 1, 2) - 10,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 1, 2) Piping - Shear Valves*
- (d) Product to be stored in each tank: (TK # 1) - Gasoline - Regular, (TK # 2) - Gasoline - Premium*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Existing dispensers to be removed. Single wall fiberglass dispenser sumps will be installed at the three locations noted on the plans. All other sumps will remain. Existing flexible piping will be brought into the new sumps. New flexible entry boots and shear valve will be installed with the new sumps. New Gilbarco Encore dispensers will be installed.

The spill bucket on tank #2 will be repaired and tested (the source of the fail seems to be a faulty fill cap). The overfill alarm will be repaired (appears to need a new light bulb). A third party testing company will be hired to test the sacrificial anode system and complete the annual leak detection certification.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Oil Equipment Company, Inc.
4701 Lien Road
Madison, WI 53704

Contact Person: TJ Winkler
Phone: (608) 249-2881
Contractor Registration # IL1318 Exp. 10/29/2020

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File