



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2026098
Permit # 00873-2020REM
Request Rec'd 06/17/2020
Amended Date
Approval Date 6/17/2020 DS
Permit Expires 12/17/2020

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Union Pacific Railroad 4823 N. 119th Street Milwaukee, WI 53225 Contact: Kevin Peterburs (414) 267-4164	(2) <u>FACILITY</u> - name and address where tanks are located: Union Pacific RR - Global 2 Yard 301 Lake Street Northlake, IL 60164 Contact: Kevin Peterburs (414) 267-4164
--	---

(3) REMOVAL OF TANKS:

- (a) Number and size of tanks being removed: (TK # 5) - 500*
- (b) Description/location of piping being removed:*
- (c) Product to be stored in each tank: (TK # 5) - Diesel Fuel*
- (d) Reason of tanks being removed:*
- (e) If tank(s) is leaking, indicate IEMA incident number:*
- (f) Date each tank was last used: (TK # 5) - 1/1/1990*

- (4)** The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

- (5) SPECIAL CONTINGENCIES** : Obtain state and local tank removal permits under existing OSFM license.

Mobilize tank cleaning trailer, mini sucker & tank cleaning crew to site.
Excavate and expose the one 500-gallon UST and piping
Inert the UST with carbon dioxide gas or purge to remove flammable vapors as-needed.
Cut and clean the UST using a high-pressure steam washer with a solution of trisodium phosphate.
Collect tank wash waters remain in UST with vacuum truck for disposal off site at WWTP.
Remove associated piping including fill, vent, and product lines.
Issue clean tank cert & Haul the tank & associated piping away for disposal.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

HEPACO, LLC
8184 STARWOOD DR.
Loves Park, IL 61111

Contact Person: PATRICIA TUBBY
Phone: (815) 885-4841
Contractor Registration # IL002432 Exp. 9/25/2020

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist
Division File