



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

FOR OFFICE USE ONLY

Facility # 2022450
Permit # 00874-2020REM
Request Rec'd 06/17/2020
Amended Date 06/17/2020 DS
Approval Date 6/17/2020 DS
Permit Expires 12/17/2020

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Little City Foundation 1760 W Algonquin Rd Palatine, IL 60067 Contact: Larry Shinhoister (847) 489-8595	(2) <u>FACILITY</u> - name and address where tanks are located: Little City Foundation 1760 W Algonquin Rd, Bldgs 1640, 1645 Palatine, IL 60067 Contact: Trevor Roberts (847) 489-8595
---	--

(3) REMOVAL OF TANKS:

(a) *Number and size of tanks being removed: (TK # 4) - 2,000, (TK # 5) - 1,000*

(b) *Description/location of piping being removed:*

(c) *Product to be stored in each tank: (TK # 4) - Gasoline, (TK # 5) - Diesel Fuel*

(d) *Reason of tanks being removed:*

(e) *If tank(s) is leaking, indicate IEMA incident number: 2020-0491*

(f) *Date each tank was last used: (TK # 4, 5) - 8/30/2019*

(4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) SPECIAL CONTINGENCIES :

Tanks and piping to be removed.

Amendment Reason: Add tank 5

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

RW Collins Company
7225 West 66th Street
Chicago, IL 60638

Contact Person: Alisa Anderson
Phone: (708) 458-6868
Contractor Registration # IL772 Exp. 2/9/2022

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist
Division File