



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2010858
Permit # 00924-2020UPG
Request Rec'd 06/26/2020
Amended Date
Approval Date 6/29/2020 DS
Permit Expires 12/29/2020

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Lehigh Gas Wholesale Services 600 Hamilton, Suite 500 Allentown, PA 18101 Contact: Danielle Unruh (610) 625-8086	(2) <u>FACILITY</u> - name and address where tanks are located: BP - IL0007 9595 Lincoln Hwy. Frankfort, IL 60423 Contact: Vijendra Solanki (773) 716-9874
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 9) - 15,000, (TK # 10, 11) - 10,000, (TK # 12) - 6,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 9, 10, 11, 12) Piping - Flexible Double Wall A.P.T. Poly Tech P150SC, (TK # 9, 10, 11, 12) Piping - Other Steel Riser, (TK # 9, 10, 11, 12) Piping - Ball Valves, (TK # 9, 10, 11, 12) Piping - Shear Valves, (TK # 9, 10, 11, 12) Piping - Flex Connector Steel*
- (d) *Product to be stored in each tank: (TK # 9, 10) - Gasoline - Regular, (TK # 11) - Gasoline - Premium, (TK # 12) - Diesel Fuel*
- (e) *Type of leak detection being used:*
- Tank:*
- Piping: (TK # 9, 10, 11, 12) Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown*
- (f) *Corrosion Protection being used:*
- Tank:*
- Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES** : Relocate piping within the existing dispenser sumps to accommodate 4 new dispensers over the adjacent, existing piping sumps. Relocate 2 new dispensers over new adjacent piping sumps with the product piping coming from adjacent existing piping sump.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

B & K Equipment Company
2939 175th Street


Contact Person: Ed Angell

Lansing IL 60438

Phone: (708) 474-3344

Contractor Registration # IL1207 Exp. 2/14/2022

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File