



Office of the Illinois State Fire Marshal  
 Division of Petroleum and Chemical Safety  
 1035 Stevenson Drive  
 Springfield, IL 62703  
 2177851020

**FOR OFFICE USE ONLY**  
 Facility # 2044763  
 Permit # 01654-2019UPG  
 Request Rec'd 09/03/2019  
 Amended Date 07/06/2020 DS  
 Approval Date 9/3/2019 DS  
 Permit Expires 9/3/2020

**Extended/Amended**

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Costco Wholesale Corporation        P.O. Box 35005        Seattle, WA 98124</p> <p>Contact: Jay Grubb (206) 313-8100</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Costco Gasoline #1088        830 E Boughton Road        Bolingbrook, IL 60490</p> <p>Contact: Matthew Welko (425) 313-8100</p>
--	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired: (TK # 1, 2, 3) - 20,000, (TK # 4) - 1,500*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 1, 2, 3) Piping - Other Submersible Pump, (TK # 1, 2, 3) Piping - Shear Valves, (TK # 1, 2, 3) Piping - Flex Connector Steel, (TK # 3, 4) Piping - Fiberglass Double Wall A.O. Smith, (TK # 3) Piping - Ball Valves*
- (d) *Product to be stored in each tank: (TK # 1, 2, 3) - Gasoline, (TK # 4) - Lubrizol - Fuel Additive*
- (e) *Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) *Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) *Spill containment devices, piping, and dispenser containmnt devices: (TK # 1, 2, 3) Spill Contain Device - Single Wall Spill Bucket OPW FibreTite Multi-port*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

Expanding canopy to install (6) new dispensers and islands. Installing (1) new submersible in (3) existing tanks. New multi-port fill sumps on (3) existing tanks. Installing a new 30,000 gallon tank on install permit. Tying on to existing premium piping from tank 3 to feed the (6) new dispensers. Tying on to existing additive line to feed the new 30,000 gallon tank.


Amendment Reason: Replacing the flex connectors, shear valves and misc steal fittings under the existing 6 dispensers.

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Stenstrom Petroleum Services Group  
2422 Center Street  
Rockford, IL 61108

Contact Person: Robert Stenstrom  
Phone: (815) 398-6250  
Contractor Registration # IL1890 Exp. 4/12/2020

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in black ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File