



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**Amended**

**FOR OFFICE USE ONLY**

Facility # 3042596  
Permit # 01033-2020UPG  
Request Rec'd 07/22/2020  
Amended Date 07/27/2020 DS  
Approval Date 7/22/2020 DS  
Permit Expires 1/22/2021

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

|   |  |
|---|--|
| <p><b>(1) <u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Hy-Vee, Inc.<br/>5820 Westown Parkway<br/>West Des Moines, IA 50266<br/>Contact: John Brummit (515) 267-2800</p> | <p><b>(2) <u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Hy-Vee Gas - Milan<br/>810 West 1st Street<br/>Milan, IL 61264<br/>Contact: Matt Patterson 3097560108</p> |
|---|--|

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 5) - 6,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 5) Piping - Flexible Double Wall A.P.T. Poly Tech P175SC, (TK # 5) Piping - Single Wall Transition Sump*
- (d) Product to be stored in each tank: (TK # 5) - Diesel Fuel*
- (e) Type of leak detection being used:*
  - Tank:*
  - Piping: (TK # 5) Leak Detect - Piping - Non-Discriminating Sump Sensor*
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

Amendment Reason: Initial drawing submitted did not properly represent the existing diesel line run, I visited site for layout and noticed the difference, new drawing is an accurate representation of how the line runs

**NOTE:** Please see site drawing for clarification. The two existing diesel dispensers will be done away with and two transition sumps will go where those UDC's were, then the new piping will be from the two new transition sumps (old dispenser sumps) to the existing dispenser as shown in site plan

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Seneca Companies, Inc.  
4140 East 14th Street PO Box 3360  
Des Moines, IA 50313

Contact Person: Glen Davis  
Phone: (816) 761-1270  
Contractor Registration # IL598 Exp. 2/23/2022

Sincerely,



---

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File