



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 5031843
Permit # 01038-2020UPG
Request Rec'd 07/23/2020
Amended Date
Approval Date 7/27/2020 DS
Permit Expires 8/7/2020

Permit for Emergency Repair Request on 7/23/2020

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Casey's Retail Company P.O. Box 3004 3305 SE Delaware Ankeny, IA 50021 Contact: Lee Lytle (515) 965-6231	(2) <u>FACILITY</u> - name and address where tanks are located: Casey's General Store #1713 224 East Chestnut Street Mason City, IL 62664 Contact: Brock Richardson (515) 965-6238
--	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) Number and size of tanks being upgraded or repaired: (TK # 1) - 10,000

(b) Type of tanks:

(c) Type of piping: (TK # 1) Piping - Flex Connector Steel

(d) Product to be stored in each tank: (TK # 1) - Gasoline - Regular

(e) Type of leak detection being used:

Tank:

Piping:

(f) Corrosion Protection being used:

Tank:

Piping:

(g) Spill containment devices, piping, and dispenser containment devices:

(h) Overfill prevention devices:

(i) Manway accessible at grade:

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES : Replaced leaking flex connector at dispenser #1/2. Installed new Fireflex flexible connector. Performed a nitrogen test on the repair. All leaked fuels were contained in the under dispenser containment sump. Sump was cleaned and fuels were returned to the UST.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Total Petroleum Service Company
2421 Washington Road
Washington, IL 61571

Contact Person: Greg McCoy
Phone: (309) 694-8224
Contractor Registration # IL1079 Exp. 2/8/2022

Sincerely,

Daniel H. Starks

Daniel Starks

cc: Storage Tank Safety Specialist
Division File