



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY
Facility # 2020671
Permit # 01041-2020UPG
Request Rec'd 07/23/2020
Amended Date
Approval Date 7/27/2020 DS
Permit Expires 1/27/2021

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Fazal Karim, LLC 24304 S. Volbrecht Road Crete, IL 604172653</p> <p>Contact: Ketanchandra Bhai (773) 294-2482</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Mobil Evanston 140 Chicago Avenue Evanston, IL 60202</p> <p>Contact: Ketan Bhai (847) 869-2920</p>
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 4) - 15,000, (TK # 5) - 8,000, (TK # 6) - 7,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 4, 5, 6) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX from existing tanks to new dispensers as shown in site plan, (TK # 4, 5, 6) Piping - Shear Valves, (TK # 4, 5, 6) Piping - Double Wall STP/Tanktop Sump*
- (d) *Product to be stored in each tank: (TK # 4) - Gasoline - Regular, (TK # 5) - Gasoline - Premium, (TK # 6) - Diesel Fuel*
- (e) *Type of leak detection being used:*
 - Tank: (TK # 4, 5, 6) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350*
 - Piping: (TK # 4, 5, 6) Leak Detect - Piping - Electronic Pressurized Line Leak Detection, (TK # 4, 5, 6) Leak Detect - Piping - Stand Alone Sensor Sump Sensor Non-Discriminating in all submersible and dispenser sumps*
 - NOTE: Sensors MUST shut down the submersible pump supplying that line upon detection of a leak*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containmnt devices: (TK # 4, 5, 6) Spill Contain Device - Double Wall Spill Bucket*
- (h) *Overfill prevention devices: (TK # 4, 5, 6) Overfill Prev Device - Overfill Drop Tube Valve, (TK # 4, 5, 6) Overfill Prev Device - Overfill Alarm*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.


(5) SPECIAL CONTINGENCIES :

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
Constellation Petroleum	Contact Person: Mohammed Hussain

27W441 Williams St.
Winfield, IL 601901518

Phone: (773) 507-0221
Contractor Registration # IL002438 Exp. 5/9/2021

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File