



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY
Facility # 6024946
Permit # 01042-2020UPG
Request Rec'd 07/24/2020
Amended Date
Approval Date 7/27/2020 DS
Permit Expires 1/27/2021

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>BT-OH, LLC 55 Glenlake Parkway, NE Formerly United Parcel Service/Bookind Corporation Atlanta, GA 30346 Contact: Eric Kazonovitz (404) 828-7926</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>UPS Distribution Center 1149 East Airline Drive East Alton, IL 62024 Contact: Christison Steve (618) 259-5750</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:


- (a) Number and size of tanks being upgraded or repaired: (TK # 1) - 12,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 1) Piping - Fiberglass Double Wall , (TK # 1) Piping - Ball Valves , (TK # 1) Piping - Flex Connector Steel, (TK # 1) Piping - Single Wall STP/Tanktop Sump*
- (d) Product to be stored in each tank: (TK # 1) - Gasoline - Regular*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : Install new STP sump. Modify the existing double wall product piping to install the new sump. Install new ball valve and flex connector. The existing Submerged pump, mechanical leak detection and sump sensor will remain in use.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
UPC Enterprises, LC d/b/a United Petroleum Service 4444 Union Blvd. St. Louis, MO 63115	Contact Person: Terry Smith Phone: (314) 241-3767 Contractor Registration # IL002402 Exp. 2/10/2022

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File