



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2033917
Permit # 01062-2020UPG
Request Rec'd 07/21/2020
Amended Date
Approval Date 7/30/2020 DS
Permit Expires 2/1/2021

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Brookind Corporation 400 Perimeter Terrace North Atlanta, GA 30346 Contact: Jeff Krasowski (770) 913-6054	(2) <u>FACILITY</u> - name and address where tanks are located: United Parcel Service One UPS Way Hodgkins, IL 60525 Contact: Jennifer Perry (708) 387-4209
---	---

(3) UPGRADE OR REPAIR OF TANKS:

(a) Number and size of tanks being upgraded or repaired: (TK # 3) - 20,000

(b) Type of tanks:

(c) Type of piping: (TK # 3) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX from existing tank to dispensers as shown in site plan, (TK # 3) Piping - Other Submersible Pump, (TK # 3) Piping - Ball Valves, (TK # 3) Piping - Shear Valves, (TK # 3) Piping - Flex Connector Steel, (TK # 3) Piping - Single Wall STP/Tanktop Sump

(d) Product to be stored in each tank: (TK # 3) - Diesel Fuel

(e) Type of leak detection being used:

Tank:

Piping: (TK # 3) Leak Detect - Piping - Stand Alone Sensor Sump Sensor Non-Discriminating in submersible and ass dispenser sumps

NOTE: Sensors must be wired for positive shut down

(f) Corrosion Protection being used:

Tank:

Piping:

(g) Spill containment devices, piping, and dispenser containmnt devices:

(h) Overfill prevention devices:

(i) Manway accessible at grade:

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Remove existing dispensers and store on site for re-install

Remove existing piping tank and under dispenser sumps

Supply and install single wall tank and under dispenser sumps all by OPW

Run new Ameron LCX double wall product piping from submersible to master dispensers and from master to satellite dispensers
Perform all required sump and pipe testing
Backfill and resurface

NOTE: Removal permit for piping has been issued


Replaced piping exceeds 20 feet or 50% of the total pipe run.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Stenstrom Petroleum Services Group
2422 Center Street
Rockford, IL 61108

Contact Person: Robert Stenstrom
Phone: (815) 398-6250
Contractor Registration # IL1890 Exp. 4/12/2022

Sincerely,

A handwritten signature in cursive script, reading "Daniel G. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File